



Co-funded by the
Erasmus+ Programme
of the European Union

Differences between two photovoltaic systems in irrigation

Corneliu Zediu

"Vasile Alecsandri" University of Bacau

Case study tutor:	Lluis Monjo
Renewable energies tutor:	Jose Segarra Murria
Rural development tutor:	Vicent Querol
English tutor:	Csaba Szűcs
Professional supervisor:	Zsuzsanna Kray

UMANS – Urbanisme I Medi Ambient Nebot I Segarra

La Vall d'Uixó, March-April 2017

Location and Purpose



A




The project aims to develop a photovoltaic power supply system for an irrigation pump located near the town of Jérica in Castellón, Spain

Agricultural area

- 75660 m²
- 30 ha of almonds;
- 3 ha lavender;

Photovoltaic installation



The Actual System




Generator CTM-60 L, Carod

➤ 8.59 l/h;

➤ 1.120 €/l

≈ 9225.66 Liters of fuel



10332.74 €/ an




≈ 27.7 equivalent tCO₂

Sizing of the plantinstalației



The need for irrigation hours

Monts	Mar.	Apr.	Mai	Iun	Iul	Aug.	Sept	Oct.	Nov.
Hour	3	4	4	5	5	5	4	3	2



Producer		HN Bombas	
Model		GJ012-25	
kW	HP	11	15
Tension		400 V	
Frequency		50 Hz	

First plantinstalație



68 Panouri Fotovoltaice AS-6p-310

- 4 rânduri (4 x 17 panouri)
- 21.08 kW.



Producer	Amerisolar
Model	AS-6P-310
Nominal power(P_{max})	310 W
Open circuit voltage(V_{oc})	45.5 V
Short circuit current(I_{sc})	8.85 A
Voltage at rated power(V_{mp})	36.9 V
Current at nominal power(I_{mp})	8.41 A
Efficiency (%)	15.98




Producer	Baico
Model	Iskut Solar 425
V in (VDC)	320 - 850 V
Vin P1 nom* (VDC)	> 560 V
Max V out (VAC)	3 x 400 V
Max I out (A)	25
Weight	8.5 kg

2nd installation

52 Photovoltaic Panels AS-6p-310

4 rows (4x 13 panels)

16.12 kW.



Producer	Schneider Electric
Model	XW MPPT 80 600
Battery nominal voltage	24 and 48 V
Voltage panels	195 to 550 V
Maximum voltage	600 V
Battery voltage	16 to 67 VDC
Load current	35A (28 A @STC)
Maximum charge current	80 A



➤ 24 Units

Producer	Tab+
Model	12 OPzS 1500
Voltage	2 V
Ah C10	1613



Producer	Schneider Electric
Model	Conext XW+ 5548 NA
Power at 25°C	5500 W
Power at 40°C	4500 W
Frequency at exit	50 / 60 Hz
Input voltage intrare	42 / 60 V (48 nominal)
Maximum input current	150 A



Genesal Generator XS Power Gen22KC

- 16 kW
- 4 l/oră
- 3108 €

Investiția. Indicatori economici

Prodct	Price per unit(€)	Total (€)
Photovoltaic panels (68)	214	14552
VFD	2210.68	2210.68
Structure	50	3400
Cables and auxiliary elements	0.264	5565.12
Personal	0.119	2508.52
Proiectare	2200	2200
Total	≈ 1.444 €/Wp	30436.32

Investiția inițială a sistemului de 21 kW

Product	Price per unit (€)	Total (€)
Photovoltaic panels (52)	214	11128
MPPT (4)	921.4	3685.6
Batery (24)	458.4	11001.6
Inverter (3)	2375.24	7125.7
Structure	50	2600
Monitoring panel	764.22	764.22
Cables and auxiliary elements	0.384 €/Wp	6190.08
Personal	0.158	2546.96
Design	2800	2800
Total	≈ 2.968 €/Wp	47842.16

Initial investment of the 16 kW system

	21 kW		16 kW	
	Initial cost(€)	O&M (€/year)	Initial cost(€)	O&M (€/year)
Total	25727.8	385.92	42495.2	637.43

	Energy consumptionk Wh	Current generator			
		€ / kWh	Cost combustibil	O&M	Cost total
Anual	11770	0.878	10332.74	200	10532.74
Total	235400	0.878	206654.8	4000	210654.8

Current generator costs in 20 years

	O&M Cost 21 kW	O&M Cost 16 kW	Fuel cost	Fuel cost	21 kW PV panels (€)		16 kW PV panels (€)	
					Total Cost GA	Total Cost GS	Total Cost GA	Total Cost GS
Annual	385.92	637.43	1123.08	784	1509	1169.92	1760.51	1421.43
Total	7718.4	12748.6	22461.6	15680	30180	23398.4	35210.2	28428.6

Costs generated by systems in 20 years

LCOE	SA	PFGA 21 kW	PFGS 21 kW	PFGA 16 kW	PFGS 16 kW
€/kWh	0.895	0.338	0.506	0.743	0.684

LCOE per sistem

Annual revenue	21 kW (€)		16 kW (€)	
	GA	GS	GA	GS
	9023.74	9362.82	8772.23	9111.31

Venit per sistem

Given the revenue generated by each system, the following amortization period results:

PFGA 21 kW - 4 years (5658.64 € profit); 150038.00 € profit after 20 years;

PFGS 21 kW - 4 years (3906.96 € profit); 153712.08 € profit after 20 years;

PFGA16 kW - 6 years (4791.22 € profit); 127602.44 € profit after 20 years;

PFGS16 kW - 6 years (3717.70 € profit). 131276.04 € profit after 20 years.

Taking into account a 5% rate for net current value,

Resulting in a different amortization period:

PFGA21 kW - 4 years (1561.42 € profit); (\$ 82019.43 profit after 20 years);

PFGS21 kW - 5 years (6991.79 € profit); (83137.11 € profit after 20 years);

PFGA16 kW - 7 years (2917.24 € profit); (61479.22 € profit after 20 years);

PFGS 16 kW - 7 years (1771.28 € profit). (62596.90 € profit after 20 years).

RIR %	21 kW		16 kW	
	GA	GS	GA	GS
	28.24	26.58	17.46	17.03


Rata interna de retur

The main economic and technological disadvantages and disadvantages in irrigation


First plant		The second installation	
Benefits <ul style="list-style-type: none"> ➤ Changing the frequency from 50 Hz to 40 Hz can extend the irrigation period. ➤ Network losses are lower due to the small number of equipment; ➤ Low initial cost as well as a small O & M cost. 	Disadvantages <ul style="list-style-type: none"> ➤ Can not provide energy requirements under low irradiation conditions; ➤ Large number of photovoltaic panels. 	Benefits <ul style="list-style-type: none"> ➤ Ensure energy needs at any time of day due to batteries; ➤ Low number of photovoltaic panels. 	Disadvantages <ul style="list-style-type: none"> ➤ High network losses due to the large number of equipment; ➤ Batteries generate an extra cost when they change (10 years); ➤ Initial cost, high O & M.

Impact on the environment

Total	Annual equivalent emissions		
	Actual Generator	PFGA	PFGS
	27739.59	2798	1953



Social Impact and Rural Development



Social Impact and Rural
Development

Cheaper products

Energy at
low cost •

Plus competitive

Marketing

School Trips

Conclusion

It has come to the conclusion that the 21kW photovoltaic plant equipped with the frequency converter is optimal in this situation due to:

- Possibility to extend the irrigation period by changing the frequency from 50 Hz to 40 Hz;
- Initial investment is low (30436.32 €);
- Fast depreciation (4-5 years);
- Poor pollution of the generator.



Thank you for your attention

Corneliu Zediu