

# Differences between two photovoltaic systems in irrigation

**Corneliu Zediu**

**"Vasile Alecsandri" University of Bacau**

Case study tutor:

Lluis Monjo

Renewable energies tutor:

Jose Segarra Murria

Rural development tutor:

Vicent Querol

English tutor:

Csaba Szűcs

Professional supervisor:


Zsuzsanna Kray

**UMANS – Urbanisme I Medi Ambient Nebot I Segarra**

La Vall d'Uixó, March-April 2017

# Location and Purpose

A




The project aims to develop a photovoltaic power supply system for an irrigation pump located near the town of Jérica in Castellón, Spain

Agricultural area

- 75660 m<sup>2</sup>
- 30 ha of almonds;
- 3 ha lavender;

# Photovoltaic installation



# The Actual System



Generator CTM-60 L, Carod

➤ 8.59 l/h;  
➤ 1.120 €/l

≈ 9225.66 Liters of fuel

10332.74 €/ an




≈ 27.7 equivalent tCO<sub>2</sub>

# Sizing of the plantinstalației



The need for irrigation hours

Monts	Mar.	Apr.	Mai	Iun	Iul	Aug.	Sept	Oct.	Nov.
Hour	3	4	4	5	5	5	4	3	2



Producer	HN Bombas	
Model	GJ012-25	
kW	HP	11 15
Tension	400 V	
Frequency	50 Hz	

# First plantinstalație



68 Panouri Fotovoltaice AS-6p-310

- 4 rânduri (4 x 17 panouri)
- 21.08 kW.






Producer	Amerisolar
Model	AS-6P-310
Nominal power( $P_{max}$ )	310 W
Open circuit voltage( $V_{oc}$ )	45.5 V
Short circuit current( $I_{sc}$ )	8.85 A
Voltage at rated power( $V_{mp}$ )	36.9 V
Current at nominal power( $I_{mp}$ )	8.41 A
Efficiency (%)	15.98

Producer	Baico
Model	Iskut Solar 425
V in (VDC)	320 - 850 V
Vin P1 nom* (VDC)	> 560 V
Max V out (VAC)	3 x 400 V
Max I out (A)	25
Weight	8.5 kg

# 2nd installation

52 Photovoltaic Panels AS-6p-310  
4 rows (4x 13 panels)  
16.12 kW.



Producer	Schneider Electric
Model	XW MPPT 80 600
Battery nominal voltage	24 and 48 V
Voltage panels	195 to 550 V
Maximum voltage	600 V
Battery voltage	16 to 67 VDC
Load current	35A (28 A @ STC)
Maximum charge current	80 A



➤ 24 Units

Producer	Tab+
Model	12 OPzS 1500
Voltage	2 V
Ah C10	1613



Producer	Schneider Electric
Model	Conext XW+ 5548 NA
Power at 25°C	5500 W
Power at 40°C	4500 W
Frequency at exit	50 / 60 Hz
Input voltagee intrare	42 / 60 V (48 nominal)
Maximum input current	150 A



## Genesal Generator XS Power Gen22KC

- 16 kW
- 4 l/oră
- 3108 €

# Investiția. Indicatori economici

Prodct	Price per unit(€)	Total (€)
Photovoltaic panels (68)	214	14552
VFD	2210.68	2210.68
Structure	50	3400
Cables and auxiliary elements	0.264	5565.12
Personal	0.119	2508.52
Proiectare	2200	2200
Total	≈ 1.444 €/Wp	30436.32

Investiția inițială a sistemului de 21 kW

Product	Price per unit (€)	Total (€)
Photovoltaic panels (52)	214	11128
MPPT (4)	921.4	3685.6
Batery (24)	458.4	11001.6
Inverter (3)	2375.24	7125.7
Structure	50	2600
Monitoring panel	764.22	764.22
Cables and auxiliary elements	0.384 €/Wp	6190.08
Personal	0.158	2546.96
Design	2800	2800
Total	≈ 2.968 €/Wp	47842.16

Initial investment of the 16 kW system

	21 kW		16 kW	
	Initial cost(€)	O&M (€/year)	Initial cost(€)	O&M (€/year)
<b>Total</b>	<b>25727.8</b>	<b>385.92</b>	<b>42495.2</b>	<b>637.43</b>

	Energy consumption Wh	Current generator			
		€ / kWh	Cost combustible	O&M	Cost total
Anual	11770	0.878	10332.74	200	10532.74
<b>Total</b>	<b>235400</b>	<b>0.878</b>	<b>206654.8</b>	<b>4000</b>	<b>210654.8</b>

*Current generator costs in 20 years*

	O&M Cost 21 kW	O&M Cost 16 kW	Fuel cost	Fuel cost	21 kW PV panels (€)		16 kW PV panels (€)	
					Total Cost GA	Total Cost GS	Total Cost GA	Total Cost GS
Annual	385.92	637.43	1123.08	784	1509	1169.92	1760.51	1421.43
<b>Total</b>	<b>7718.4</b>	<b>12748.6</b>	<b>22461.6</b>	<b>15680</b>	<b>30180</b>	<b>23398.4</b>	<b>35210.2</b>	<b>28428.6</b>

*Costs generated by systems in 20 years*

LCOE	SA	PFGA 21 kW	PFGS 21 kW	PFGA 16 kW	PFGS 16 kW
€/kWh	0.895	0.338	0.506	0.743	0.684

LCOE per sistem

Annual revenue	21 kW (€)		16 kW (€)	
	GA	GS	GA	GS
	9023.74	9362.82	8772.23	9111.31

Venit per sistem

Given the revenue generated by each system, the following amortization period results:

PFGA 21 kW - 4 years (5658.64 € profit); 150038.00 € profit after 20 years;  
 PFGS 21 kW - 4 years (3906.96 € profit); 153712.08 € profit after 20 years;  
 PFGA16 kW - 6 years (4791.22 € profit); 127602.44 € profit after 20 years;  
 PFGS16 kW - 6 years (3717.70 € profit). 131276.04 € profit after 20 years.

Taking into account a 5% rate for net current value,  
Resulting in a different amortization period:

PFGA21 kW - 4 years (1561.42 € profit); (\$ 82019.43 profit after 20 years);  
PFGS21 kW - 5 years (6991.79 € profit); (83137.11 € profit after 20 years);  
PFGA16 kW - 7 years (2917.24 € profit); (61479.22 € profit after 20 years);  
PFGS 16 kW - 7 years (1771.28 € profit). (62596.90 € profit after 20 years).

RIR %	21 kW		16 kW	
	GA	GS	GA	GS
	28.24	26.58	17.46	17.03


Rata interna de return

# The main economic and technological disadvantages and disadvantages in irrigation


First plant	Disadvantages	The second installation	Disadvantages
Benefits <ul style="list-style-type: none"><li>➤ Changing the frequency from 50 Hz to 40 Hz can extend the irrigation period.</li><li>➤ Network losses are lower due to the small number of equipment;</li><li>➤ Low initial cost as well as a small O &amp; M cost.</li></ul>	<ul style="list-style-type: none"><li>➤ Can not provide energy requirements under low irradiation conditions;</li><li>➤ Large number of photovoltaic panels.</li></ul>	<ul style="list-style-type: none"><li>➤ Ensure energy needs at any time of day due to batteries;</li><li>➤ Low number of photovoltaic panels.</li></ul>	<ul style="list-style-type: none"><li>➤ High network losses due to the large number of equipment;</li><li>➤ Batteries generate an extra cost when they change (10 years);</li><li>➤ Initial cost, high O &amp; M.</li></ul>

# Impact on the environment

Total	Annual equivalent emissions		
	Actual Generator	PFGA	PFGS
	27739.59	2798	1953



# Social Impact and Rural Development



# Conclusion

It has come to the conclusion that the 21kW photovoltaic plant equipped with the frequency converter is optimal in this situation due to:

- Possibility to extend the irrigation period by changing the frequency from 50 Hz to 40 Hz;
- Initial investment is low (30436.32 €);
- Fast depreciation (4-5 years);
- Poor pollution of the generator.



Thank you for your attention

Corneliu Zediu